



***Town of Wells, Maine
Code Enforcement Office***

*JODINE A. ADAMS, CODE ENFORCEMENT OFFICER
BARBARA B. GAGNON, CODE ENFORCEMENT OFFICER
DAVID A. JOHNSON, CODE ENFORCEMENT OFFICER
JAMES R. GENEREUX, CODE ENFORCEMENT OFFICER*

*208 Sanford Rd., Wells, Maine 04090
Voice: (207) 646-5187
Fax: (207) 646-2935
Website: www.wellstown.org*

October 29, 2014

Charles Fraser
5 Pine Ledge Drive
Wells, Maine 04090

Re: Water Test Results 2014

Dear Mr. Fraser:

Enclosed you will find results of the water test taken from your property on October 9, 2014.

The results will be reviewed within the next 30 days by Richard Behr at the Division of Remediation from the Department of Environmental Protection. If you have any further questions he may be reached at 207-287-7688.

Sincerely,

A handwritten signature in cursive script, appearing to read "J. Adams".

Jodine L. Adams
Code Enforcement Officer & LPI

REPORT OF ANALYSIS

120 York Street Kennebunk, ME 04043
 www.nelsonanalytical.com
 (207)467-3478 phone

NELSON ANALYTICAL LAB

NELAC Accreditation #NH2018
 Maine State Certification # ME0015
 Vermont State Certification # VT2018
 Maine Radon Certification # ME17500

Job ID : 214100288

Client Name: Town of Wells	Attn: Town of Wells
Project Name:	Date Reported : 10/15/2014
Job ID : 214100288	Date Collected: 10/09/2014 02:45 PM
Client Sample ID: Town of Wells	Collected By : David
Job Sample ID: 214100288.01	Date Received : 10/10/2014 02:35 PM
Sample Location: 5 Pine Lodge Dr, Wells, ME	Sample Matrix : Drinking Water

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
pH	6.31	6.5-8.5	s.u.	10/10/2014 16:34	SM 4500H B	Secondary	Outside EPA Standard
Sulfate	22	250	mg/L	10/14/2014 13:20	SM 4500SO4-E	Secondary	Within EPA Standard
Turbidity	<1.0	5.0	NTU	10/10/2014 16:55	SM 2130B	Secondary	Within EPA Standard
Chloride	28	250	mg/L	10/10/2014 17:00	SM 4500Cl-B	Secondary	Within EPA Standard
Conductance	210	N/A	umho/cm	10/10/2014 15:45	SM 2510B	N/A	No EPA Limit
Arsenic	<0.001	0.010	mg/L	10/13/2014 19:31	EPA 200.8	Primary	Within EPA Standard
Iron	0.071	0.300	mg/L	10/13/2014 19:31	EPA 200.8	Secondary	Within EPA Standard
Manganese	0.004	0.050	mg/L	10/13/2014 19:31	EPA 200.8	Secondary	Within EPA Standard
Sodium	16	N/A	mg/L	10/13/2014 19:31	EPA 200.8	N/A	No EPA Limit
Thallium	<0.001	0.002	mg/L	10/13/2014 19:31	EPA 200.8	Primary	Within EPA Standard



This Laboratory is NELAP accredited.

Notes: mg/l=ppm, ug/l=ppb. "<" denotes "less than" This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical LLC is currently accredited by the New Hampshire Environmental Lab Accreditation program, Maine Laboratory Accreditation Program and the Vermont Laboratory Accreditation program. For a list of current accredited tests, please visit the New Hampshire DES site: <http://www2.des.nh.gov/CertifiedLabs/Certified-Method-Result.aspx?matrix=%&cat1=&method=%&analyte=%&labstate=%&labcity=%&labname=2018>, Maine Accreditation Program at the following Site: <http://www.maine.gov/dhhs/mecdc/environmental-health/water/dwp-services/labcert/labcert.htm> and the Vermont Laboratory Accreditation program at the following site: http://healthvermont.gov/enviro/ph_lab/documents/certified_labs.pdf. Sampling performed by the lab is according to the lab document Water sampling Instructions. NELAC standards require pH & Chlorine be tested immediately after sample collection. Samples will be tested as quickly as laboratory operations allow. More information can be found at <http://www.epa.gov/>, <http://des.nh.gov/> and <http://www.maine.gov/dhhs/mecdc/environmental-health/eohp/wells/mewellwater.htm>. Tests noted with NAL.1 indicated subcontracted analysis to another Nelson Analytical Laboratory



*Town of Wells, Maine
Code Enforcement Office*

*JODINE A. ADAMS, CODE ENFORCEMENT OFFICER
BARBARA B. GAGNON, CODE ENFORCEMENT OFFICER
DAVID A. JOHNSON, CODE ENFORCEMENT OFFICER
JAMES R. GENEUREUX, CODE ENFORCEMENT OFFICER*

*208 Sanford Rd., Wells, Maine 04090
Voice: (207) 646-5187
Fax: (207) 646-2935
Website: www.wellstown.org*

October 29, 2014

Roslyn Crawford
16 Pine Ledge Drive
Wells, Maine 04090

Re: Water Test Results 2014

Dear Ms. Crawford:

Enclosed you will find results of the water test taken from your property on October 9, 2014.

The results will be reviewed within the next 30 days by Richard Behr at the Division of Remediation from the Department of Environmental Protection. If you have any further questions he may be reached at 207-287-7688.

Sincerely,

A handwritten signature in black ink, appearing to read "J. Adams".

Jodine L. Adams
Code Enforcement Officer & LPI

REPORT OF ANALYSIS

120 York Street Kennebunk, ME 04043
 www.nelsonanalytical.com
 (207)467-3478 phone

NELSON ANALYTICAL LAB


NELAC Accreditation #NH2018
 Maine State Certification # ME0015
 Vermont State Certification # VT2018
 Maine Radon Certification # ME17500

Job ID : 214100288

Client Name: Town of Wells	Attn: Town of Wells
Project Name:	Date Reported : 10/15/2014
Job ID : 214100288	Date Collected: 10/09/2014 03:00 PM
Client Sample ID: Town of Wells	Collected By : David
Job Sample ID: 214100288.04	Date Received : 10/10/2014 02:35 PM
Sample Location: 16 Pine Lodge Rd, Wells, ME	Sample Matrix : Drinking Water

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
pH	7.36	6.5-8.5	s.u.	10/10/2014 16:34	SM 4500H B	Secondary	Within EPA Standard
Sulfate	31	250	mg/L	10/14/2014 13:20	SM 4500SO4-E	Secondary	Within EPA Standard
Turbidity	<1.0	5.0	NTU	10/10/2014 16:55	SM 2130B	Secondary	Within EPA Standard
Chloride	34	250	mg/L	10/10/2014 17:00	SM 4500Cl-B	Secondary	Within EPA Standard
Conductance	340	N/A	umho/cm	10/10/2014 15:45	SM 2510B	N/A	No EPA Limit
Arsenic	0.007	0.010	mg/L	10/13/2014 19:31	EPA 200.8	Primary	Within EPA Standard
Iron	0.113	0.300	mg/L	10/13/2014 19:31	EPA 200.8	Secondary	Within EPA Standard
Manganese	<0.001	0.050	mg/L	10/13/2014 19:31	EPA 200.8	Secondary	Within EPA Standard
Sodium	61	N/A	mg/L	10/13/2014 19:31	EPA 200.8	N/A	No EPA Limit
Thallium	<0.001	0.002	mg/L	10/13/2014 19:31	EPA 200.8	Primary	Within EPA Standard

For Detailed Test Descriptions please visit: <http://www.nelsonanalytical.com/drinking-water-test-glossary>

Respectfully Submitted 
 [Lorri Maling]

PRIMARY: Regulated by the EPA as a health related parameter
 SECONDARY: Aesthetic parameter - not regarded as a health concern



This Laboratory is NELAP accredited.

Notes: mg/l=ppm, ug/l=ppb. "<" denotes "less than" This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical LLC is currently accredited by the New Hampshire Environmental Lab Accreditation program, Maine Laboratory Accreditation Program and the Vermont Laboratory Accreditation program. For a list of current accredited tests, please visit the New Hampshire DES site: <http://www2.des.nh.gov/CertifiedLabs/Certified-Method-Result.aspx?matrix=%&cat1=8&method=%&analyte=%&labstate=%&labcity=%&labname=2018>, Maine Accreditation Program at the following Site: <http://www.maine.gov/dhhs/mecdc/environmental-health/water/dwp-services/labcert/labcert.htm> and the Vermont Laboratory Accreditation program at the following site: http://healthvermont.gov/enviro/ph_lab/documents/certified_labs.pdf. Sampling performed by the lab is according to the lab document Water sampling Instructions. NELAC standards require pH & Chlorine be tested immediately after sample collection. Samples will be tested as quickly as laboratory operations allow. More information can be found at <http://www.epa.gov/>, <http://des.nh.gov/> and <http://www.maine.gov/dhhs/mecdc/environmental-health/eohp/wells/mewellwater.htm>. Tests noted with NAL.1 indicated subcontracted analysis to another Nelson Analytical Laboratory



***Town of Wells, Maine
Code Enforcement Office***

*JODINE A. ADAMS, CODE ENFORCEMENT OFFICER
BARBARA B. GAGNON, CODE ENFORCEMENT OFFICER
DAVID A. JOHNSON, CODE ENFORCEMENT OFFICER
JAMES R. GENEUX, CODE ENFORCEMENT OFFICER*

*208 Sanford Rd., Wells, Maine 04090
Voice: (207) 646-5187
Fax: (207) 646-2935
Website: www.wellstown.org*

October 29, 2014

Richard Byrne
461 Littlefield Road
Wells, Maine 04090

Re: Water Test Results 2014

Dear Mr. Byrne:

Enclosed you will find results of the water test taken from your property on October 9, 2014.

The results will be reviewed within the next 30 days by Richard Behr at the Division of Remediation from the Department of Environmental Protection. If you have any further questions he may be reached at 207-287-7688.

Sincerely,

A handwritten signature in cursive script, appearing to read "J. Adams".

Jodine L. Adams
Code Enforcement Officer & LPI



*Town of Wells, Maine
Code Enforcement Office*

*JODINE A. ADAMS, CODE ENFORCEMENT OFFICER
BARBARA B. GAGNON, CODE ENFORCEMENT OFFICER
DAVID A. JOHNSON, CODE ENFORCEMENT OFFICER
JAMES R. GENEUREUX, CODE ENFORCEMENT OFFICER*

*208 Sanford Rd., Wells, Maine 04090
Voice: (207) 646-5187
Fax: (207) 646-2935
Website: www.wellstown.org*

October 29, 2014

Ralph Robinson
416 Littlefield Road
Wells, Maine 04090

Re: Water Test Results 2014

Dear Mr. Robinson:

Enclosed you will find results of the water test taken from your property on October 9, 2014.

The results will be reviewed within the next 30 days by Richard Behr at the Division of Remediation from the Department of Environmental Protection. If you have any further questions he may be reached at 207-287-7688.

Sincerely,

A handwritten signature in cursive script, appearing to read "J. Adams".

Jodine L. Adams
Code Enforcement Officer & LPI

REPORT OF ANALYSIS

120 York Street Kennebunk, ME 04043
 www.nelsonanalytical.com
 (207)467-3478 phone

NELSON ANALYTICAL LAB

NELAC Accreditation #NH2018
 Maine State Certification # ME0015
 Vermont State Certification # VT2018
 Maine Radon Certification # ME17500

Job ID : 214100288

Client Name: Town of Wells Attn: Town of Wells
 Project Name: Date Reported : 10/15/2014

Job ID : 214100288 Date Collected: 10/09/2014 03:30 PM
 Client Sample ID: Town of Wells Collected By : David
 Job Sample ID: 214100288.02 Date Received : 10/10/2014 02:35 PM
 Sample Location: 416 Littlefield Rd, Wells, ME Sample Matrix : Drinking Water

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
pH	6.96	6.5-8.5	s.u.	10/10/2014 16:34	SM 4500H B	Secondary	Within EPA Standard
Sulfate	20	250	mg/L	10/14/2014 13:20	SM 4500SO4-E	Secondary	Within EPA Standard
Turbidity	<1.0	5.0	NTU	10/10/2014 16:55	SM 2130B	Secondary	Within EPA Standard
Chloride	54	250	mg/L	10/10/2014 17:00	SM 4500Cl-B	Secondary	Within EPA Standard
Conductance	360	N/A	umho/cm	10/10/2014 15:45	SM 2510B	N/A	No EPA Limit
Arsenic	0.003	0.010	mg/L	10/13/2014 19:31	EPA 200.8	Primary	Within EPA Standard
Iron	0.136	0.300	mg/L	10/13/2014 19:31	EPA 200.8	Secondary	Within EPA Standard
Manganese	<0.001	0.050	mg/L	10/13/2014 19:31	EPA 200.8	Secondary	Within EPA Standard
Sodium	23	N/A	mg/L	10/13/2014 19:31	EPA 200.8	N/A	No EPA Limit
Thallium	<0.001	0.002	mg/L	10/13/2014 19:31	EPA 200.8	Primary	Within EPA Standard



This Laboratory is NELAP accredited.

Notes: mg/l=ppm, ug/l=ppb. "<" denotes "less than" This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical LLC is currently accredited by the New Hampshire Environmental Lab Accreditation program, Maine Laboratory Accreditation Program and the Vermont Laboratory Accreditation program. For a list of current accredited tests, please visit the New Hampshire DES site: <http://www2.des.nh.gov/CertifiedLabs/Certified-Method-Result.aspx?matrix=%&cat1=%&method=%&analyte=%&labstate=%&labcity=%&labname=2018>, Maine Accreditation Program at the following Site: <http://www.maine.gov/dhhs/mecdc/environmental-health/water/dwp-services/labcert/labcert.htm> and the Vermont Laboratory Accreditation program at the following site: http://healthvermont.gov/enviro/ph_lab/documents/certified_labs.pdf. Sampling performed by the lab is according to the lab document Water sampling Instructions. NELAC standards require pH & Chlorine be tested immediately after sample collection. Samples will be tested as quickly as laboratory operations allow. More information can be found at <http://www.epa.gov/>, <http://des.nh.gov/> and <http://www.maine.gov/dhhs/mecdc/environmental-health/eohp/wells/mewellwater.htm>. Tests noted with NAL.1 indicated subcontracted analysis to another Nelson Analytical Laboratory